

MANUFACTURER'S DECLARATION OF CONFORMITY

We:

di-soric GmbH & Co. KG
Steinbeisstraße 6
73660 Urbach Germany

declare under our own responsibility that the product(s):

OGWSD-25G3-T3	"IO-Link Device"
OGWSD-40G3-T3	"IO-Link Device"
OGWSD-70G3-T3	"IO-Link Device"
OGWSD-100G3-T3	"IO-Link Device"
OGWSD-150G3-T3	"IO-Link Device"
OGWSD-250G3-T3	"IO-Link Device"
OGWSD-300G3-T3	"IO-Link Device"

to which this declaration refers conform to:

- ☒ IO-Link Interface and System Specification, V1.1.3, June 2019
(NOTE 1,2)
- ☒ IO Device Description, V1.1.3, January 2021
- ☒ Additional conformance to Device Profiles
(If checked refer to Part A on page 2)
- ☐ Conformance exceptions
(If checked refer to Part B on page 2)

The conformity tests are documented in the test report(s):

IO-Link-DTR_OGWSD-25G3-T3_1.2409.000
IO-Link-DTR_OGWSD-40G3-T3_1.2409.000
IO-Link-DTR_OGWSD-70G3-T3_1.2409.000
IO-Link-DTR_OGWSD-100G3-T3_1.2409.000
IO-Link-DTR_OGWSD-150G3-T3_1.2409.000
IO-Link-DTR_OGWSD-250G3-T3_1.2409.000
IO-Link-DTR_OGWSD-300G3-T3_1.2409.000

Issued at Urbach, 17.05.2024

Authorized signatory

Name: *i. V. Stephan Korbmacher*
Title: *Director R&D*

Signature: *i. V. Stephan Korbmacher*

Reproduction and all distribution without written authorization prohibited

NOTE 1 Relevant Test specification is V1.1.3, January 2021
NOTE 2 Additional validity in Package 2020 and Corrigendum

MD-Version: V1.1.3 / 2024-05

Part A - Additional conformance to Device Profiles

	Specification
<input type="checkbox"/>	IO-Link Common Profile Specification, V1.2, Jan. 2024
<input checked="" type="checkbox"/>	IO-Link Common Profile Specification, V1.1, Dec. 2021
<input type="checkbox"/>	IO-Link Profile BLOB Transfer & Firmware Update Specification, V1.1, Sept. 2019
<input type="checkbox"/>	IO-Link Smart Sensors 2 nd Edition Specification, V1.2, Jan. 2024
<input checked="" type="checkbox"/>	IO-Link Smart Sensors 2 nd Edition Specification, V1.1, Sept. 2021

Part B - Conformance exceptions

We herewith declare the following deviations to the related specifications	Reason
There are no deviations	